



^{1.} Preferred piping diagram.

- 2. The temperature and pressure relief valve setting shall not exceed pressure rating of any component in the system.
- 3. Service valves are shown for servicing unit. However, local codes shall govern their usage.

June 2011 | Printed in U.S.A. | © State Water Heaters For Technical Information and Automated Fax Service, call 800-365-0024 or visit www.statewaterheaters.com. State Water Heaters reserves the right to make product changes or improvements without prior notice.